

Hawk View

Wildfire Fire Safe Plan Amendment A

Prepared for:

Hawk View Joint Ventures

Prepared by:

**CDS Fire Prevention Planning
William F. Draper
Registered Professional Forester
#898
4645 Meadowlark Way
Placerville, CA 95667**

December, 2005


Hawk View Amendment A

Plan Approved by:



Fred Russell
Fire Marshall/Division Chief
El Dorado Hills Fire Department


12-5-05
Date



Bert Scott
Fire Prevention
California Department of Forestry
And Fire Protection

12-5-05
Date

Prepared by:



William F. Draper
RPF 838

12-5-05
Date



Hawk View Amendment A

This amendment is to the Wildfire Fire Safe Plan, October, 2005. All other conditions not specified in this amendment remain in effect.

In the original plan, the Wildfire Mitigation Measures required that Lots 34, 35, 56, and 57 have noncombustible fences along the open space with pedestrian gates. It has been determined that the pedestrian gate is not necessary for these four lots. These lots border the open space and emergency vehicle access is adjacent to these lots. Lots 34 and 35 border Open Space B and Lots 56 and 57 borders Open Space A (see attached map).

Wildfire Mitigation Measures required that Lots 28-31 have a 30 foot setback from the rear property line. This was due to the belief that these Lots were adjacent to wildland area. These Lots in fact, back up to existing lots in another development. The setback requirement is not appropriate (see attached map).